

October 18, 2021

**Repair of Covered Walkway – Palatka Campus (SJR-BID-15-2021)  
St. Johns River State College**

Architect's Job Number: 015W05

**ADDENDUM**

All items in the Addendum are incorporated into the Contract Documents.

**Item 1.**

On sheet A100, change the note on 'ROOF CORNER DETAIL 2/A100' that reads '(2) 3/8" x 3" S.S. EPOXY WEDGE ANGHOR w/ 1 1/2" WASHER, EA. ANGLE' to read '(2) 3/8" x 3" S.S. WEDGE ANGHOR w/ 1 1/2" WASHER, EA. ANGLE'

**Item 2.**

On sheet A100, change the note on 'ROOF CORNER DETAIL 2/A100' that reads 'SECURE RAFTERS TO ANGLES w/ 3/16" METAL SCREWS' to read 'SECURE RAFTERS TO ANGLES w/ 3/8" PAN HEAD BOLTS (1" LONG) WITH 1" WASHERS AND LOCKING NUT'.

End of Addendum No. 3